


NOTES:

1. DROP TEE TO BE INSTALLED MINIMUM OF 3' BELOW CONE SECTION UNLESS OTHERWISE APPROVED.
2. INSIDE DROP MANHOLE SHALL BE INSTALLED ONLY WHERE APPROVED BY THE CITY
3. INSIDE DROP CONNECTIONS SHALL NOT BE USED IN MANHOLE STRUCTURES LESS THAN 15' DEEP.
4. THE CITY MAY REQUIRE A LARGER MANHOLE WHEN THERE IS POTENTIAL FOR MORE THAN ONE INSIDE DROP CONNECTION.

	<p>City of Bremerton</p> <p>PUBLIC WORKS</p>	<p>INSIDE DROP STRUCTURE</p>	<p>6003</p>
<p>DESIGN/CONSTRUCTION STANDARDS</p>	<p>Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.</p>	<p>Revision Date 9/17/14</p>	